

PUNJAB STATE POWER CORPN. LTD
OFFICE OF CHIEF ENGINEER/COMML. PATIALA
(SALES-1)

To

✓
M/s Bharty Realty Limited,
Old Session Courts, Civil Line,
Near Fountain Chowk, Distt. Ludhiana

Memo No.

7166

/Incl.180 /Ldh Dated

14.3.11

ਵਿਸ਼ਾ:

M/s Permission for registration of application & feasibility clearance to M/s Bharty Realty Limited (Old Session Courts Civil Line) Ludhiana for new NRS connection with load / CD of 4735 KW / 3490 KVA at 11KV supply voltage. (Requisition No. 249/ DYCE/DS City West Circle, Ludhiana dated: 6.8.2010.

The matter has been considered and it has been decided to allow you to register A&A forms for release of new NRS connection with load of 4735KW/3490 KVA at 11 KV supply voltage. The load shall be released through erection of newly proposed 11 KV Bharty feeder of length 3.2 KM with XLPE cable size 150mm² on existing 11 KV Cementery Road Feeder Ludhiana as per the proposal submitted by EIC/DS, Centra Zone, Ludhiana subject to the following conditions:-

- i) Upgradation of 66 KV Ferozepur Road S/S to 220 KV and shifting of load there of and after commissioning of link between 220 KV S/S Hambran to Ferozepur Road Sub-Station.
- ii) An undertaking duly notarized will be furnished by you that PSPCL will not be responsible for any financial or other loss/damages to the applicant/consumer if his load has to be restricted by PSPCL on account of Grid/system constraints.
- iii) You can be asked to restrict your contract demand to the extent required in case of overloading of the feeding 66 KV/220 KV Sub Station or Grid/System constraints. **Further the consumer/applicant may not even be allowed to avail peak load exemptions in case of System/Grid constraints.** A duly notarized undertaking in this regard shall be submitted by you.
- iv) If any problem arises regarding right of way in the construction of 11 KV/66 KV line then PSPCL will not be responsible for any financial or other loss/damages to you due to any delay in the construction of line. A duly notarized undertaking in this regard shall also be submitted by you.

The transformer capacity allowed to you shall be 2x2000 KVA.

You are requested to get your application registered within 30 days extendable upto 60 days from the date of issue of this letter failing which this permission shall automatically be elapsed. No further extension in time limit shall be allowed for registration of your application on account of whatsoever reasons it may be. This permission shall not be any commitment on the part of PSPCL to release this load/CD. This load/CD shall be released as per policy/regulation strictly as per prescribed rules of seniority. The above load/CD shall be subject to usual power cuts/energy restrictions as

may be enforced from time to time. In case, you fail to register your A&A forms within the stipulated period, the total amount of earnest money deposited by you shall be forfeited. It is further intimated that the seniority shall be refixed according to the date of registration of A&A forms for issue of demand notice.

Release of above load and its continuance shall be subject to the usual commercial instructions/laws and by laws/as may be framed from by PSPCL/Local Authority/PUDA and State Pollution Control Authority. In the event of any contravention of any of the instructions/ laws and by laws of any of the above authorities, PSPCL shall has right to disconnect the supply as per instructions in vogue.

Sr. Xen./Sales-

For Chief Engineer/Comm
PSPCL, Patiala

Endst. No.

/Indl.182/LDH

Dated:-

Copy of the above is forwarded to EIC/DS(Central), PSPCL, Ludhiana for information and further necessary action with reference to their office Memo No. 7658 dated 06.10.10 and 10569/70 dated 10.11.2011 they shall ensure & certify before registration of A&A forms that pending documents as listed above at Sr. No.(ii) to (iv) are got deposited from the applicant firm. EIC/DS, Central Zone, Ludhiana shall obtain a copy of resolution certified by the CA from the consumer as per terms & conditions of Supply Code/COS as per decision of FCC Committee. He is requested to get the application (A&A) registered for release of load/CD within stipulated period after ensuring the compliance of conditions as imposed above and other commercial instructions as per Supply Code/Conditions of Supply & its upto date amendments in vogue on the subject. Before release of connection, PPCB NOC must be ensured. The date of registration of application be intimated to this office. The application may not be registered until is complete in all respect i.e. accompanied by all necessary documents, failing which responsibility shall lie with the concerned officers/officials registering the A&A forms. Further, may be ensured that the applicant surrenders original feasibility clearance duly signed and other documents as per terms of the feasibility clearance, at the time of registration of A&A forms as being done while complying with the demand notice.

After release of load/CD, a certificate to the effect shall be given by your office CE/Commercial with copy to CE/Planning. Exceptions and deviations, if any, during implementation of FCC decisions should be specifically brought to the notice of CE/Commercial with a copy to CE/Planning.

The above load/CD may be released only after ensuring that the above said feasibility case is clearly eligible as per ESR No. 3.3.3.3 and no outstanding disputed amount against him or their associates firm is pending other than those for which stay has been granted by the courts.

Consumer case as received is returned herewith.

Encl:As above.

Sr. Xen./Sales-

For Chief Engineer/Comm
PSPCL, Patiala

- CC:-
1. Dy.CE/DS, Suburban Circle, PSPCL, Ludhiana.
 2. Chief Engineer/Planning, PSPCL, Patiala
 3. Sr PS to CMD, PSPCL, Patiala for kind information of CMD.
 4. Sr PS to Director/Comm., PSPCL, Patiala for kind information of Director/Comm.