



भारत सरकार Government of India

विद्युत मंत्रालय Ministry of Power

केंद्रीय विद्युत प्राधिकरण Central Electricity Authority

क्षेत्रीय निरीक्षण संगठन (उत्तर) Regional Inspectorial Organization(North)

कमरा सं 328 उ०क्षे०वि०स० भवन Room No.328.NRPC Building,

18-ए शहीद जीत सिंह मार्ग 18-A Saheed Jeet Singh Marg

कटवार्गिया मगध ,नई दिल्ली -110016 Katwaria Sarai New Delhi - 110016

website: www.cea.nic.in टेली फैक्स: 011- 26510249

No. NRIO/Misc-236/ASPEN A-11/Aerocity/Delhi/14/15

dated : 17-07-2014

18

APPROVAL FOR ENERGISATION

[Under Regulation 43 of CEA (Measures relating to safety and Electric Supply) Regulations, 2010]

To,
Project-in-charge,
M/s ASPEN Buildtech Ltd.,
Asset-11, DIAL,
Aerocity, New Delhi

Subject : Inspection of Electrical installations & apparatus related to M/s ASPEN Buildtech Ltd.,Asset-11,DIAL,Aerocity,New Delhi under regulation 43 of CEA (Measures relating to safety and Electric Supply) Regulations, 2010.

- Ref: 1. Your letter No. NIL dated 13.05.2014- Application
2. Our Letter No. NRIO/Misc-236/ASPEN A-11/Aerocity/Delhi/14/66 dated 09-06-2014- Inspection Report
3. Your letter no. Nil dated 27-06-2014 &17-07-2014- Compliance Report.

Whereas the *electrical installations and apparatus related to M/s ASPEN Buildtech Ltd.,Asset-11,DIAL,Aerocity,New Delhi* were inspected by Sh. Shishir Prakash, Assistant Director-I on 30-05-2014 and the non-compliance of certain provisions/stipulations of the Regulations were conveyed to you vide our letter (Inspection Report) under reference at Sl. No.2 above and the compliance of the same has since been received vide ASPEN letter cited at Sl No. 3. The *approval for energisation of the electrical installations and apparatus related to M/s ASPEN Buildtech Ltd.,Asset-11,DIAL,Aerocity,New Delhi is hereby accorded under regulation 43* subject to the consistent compliance with relevant provisions of CEA (Measures relating to safety and Electric Supply)Regulations.2010 by M/s ASPEN Buildtech Ltd.,Asset-11,DIAL, New Delhi..

Electrical Apparatus related to M/s ASPEN Buildtech Ltd.,Asset-11,DIAL, Aerocity, New Delhi approved for energisation

Sl No.	Description	Qty
1	2000 KVA 11/4 KV dry type transformer Kirloskar Make Sl.No. 12 COD 088/5,12 COD 088/6 & 12 COD 088/7	3
2	HT composite Panel	1
3.	LT panels	6
4	HT cable	5 Runs
5	LT Bus trunking	4
6	Isolator Panel	1

Uprender Kumar
18/07/2014

The next inspection of the installation/apparatus shall be due after 2 years from the date of this inspection. The Periodicity of periodical Inspection is subject to change by Government Notification.

Upendra Kumar
18/07/2014

(Upendra Kumar)
Superintending Engineer &
Electrical Inspector to the Govt. of India

Copy to: Chief Engineer, Electrical Inspectorate Division, CEA, New Delhi